

Durham Irrigation Operator Log

Sierra Water Utility, LLC.



Month:	December	2023	
Date	Task Description/Notes	One Man Hrs and Duties (M-F)	Two Man Hrs and Duties (M-F)
12/1/2023	Performed daily checks, checked lubrication of all pumps. Responded to one USA request.	2.00	
12/4/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/5/2023	Performed daily checks, checked lubrication of all pumps. Met with North Gate Petroluem to top generator at Library site off for winter. Pulled monthly samples and delivered to Pace Labs, Inc.	3.50	
12/6/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/7/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/8/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/9/2023	Recieved a call regarding a leak at 2540 Durham Dayton Hwy. A branch had fallen on temporary riser flush out. Isolated, repaired and checked for leaks.	2.50	
12/11/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/12/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/13/2023	Performed daily checks, checked lubrication of all pumps. Calibrate level sensors at all three sites.	2.50	
12/14/2023	Performed daily checks, checked lubrication of all pumps. Calibrate level sensors at all three sites. Responded to one USA request.	3.50	
12/15/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/18/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/19/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/20/2023	Performed daily checks, checked lubrication of all pumps. Toubleshoot Holland meter not registering on XIO.	2.00	
12/21/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/22/2023	Performed daily checks, checked lubrication of all pumps. Responded to one USA request.	2.00	
12/25/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/26/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/27/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/28/2023	Performed daily checks, checked lubrication of all pumps.	1.75	
12/29/2023	Performed daily checks, checked lubrication of all pumps. Responded to one USA request.	2.00	
Monthly Production			
9,221 CCF's			
Total Regular Hours		44.50	
Total Extra Regular Hours over 48 hrs/month, excluding meter reading		-3.50	
Total Additional After Hours			0.00
Signature:	<i>Michael Butler</i>		
Title:	Chief Operator		