



Month:	May 2026		
Date	Task Description/Notes	Operator Hrs (M-F)	Plumbing Hrs / After Hrs
05/01/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/04/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/05/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/06/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/07/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/08/2026	Performed daily checks, checked lubrication of all pumps. Responded to USA request.	2.00	
05/11/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/12/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/13/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/14/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/15/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/18/2026	Performed daily checks, checked lubrication of all pumps. Responded to two USA requests. Library Site - Delivered Chlorine 37 gallons. Alley Site - Serviced Chlorinator Replaced A14T tube. Service Holland chlorinator, replaced 3/8" injector	3.00	
05/19/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/20/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/21/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/22/2026	Performed daily checks, checked lubrication of all pumps. Library Site - Delivered Chlorine 10 gallons. Alley Site - Delivered Chlorine 10 gallons.	2.25	
05/25/2026	Performed daily checks, checked lubrication of all pumps. Responded to USA request.	2.00	
05/26/2026	Performed daily checks, checked lubrication of all pumps. Responded to USA request. Respond to customer complaint of intermittent low pressure at Marsh Ct. during peak morning usage.	3.00	
05/27/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/28/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
05/29/2026	Performed daily checks, checked lubrication of all pumps.	1.75	
Monthly Production			
CCF's	19,208.37		
Total Regular Hours		40.25	
Total Plumbing Hrs One Man			
Total Plumbing Hrs Two Man			
Total After Hours			
Signature:	Michael Butler		
Title:	Chief Operator		